

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PH 61/24-25

Dated: 07/06/2024

It is certified that an inspection team headed by JAYACHANDRAN S, HEALTH INSPECTOR Gr II  
(Name of Officers with designation) from FHC PAMBOOR

(Name of Department/ Office) inspected the CHINMAYA VIDYALAYA, CHINMAYA GARDEN  
KOLAZHY

(Name & Address of the school) on 07/06/2024 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ONE YEAR



Signature of Health Inspector  
Primary Health Centre  
Pamboor-Kuttur  
Seal: JAYACHANDRAN S

Designation : HEALTH INSPECTOR Gr II

Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department : .....


To

PRINCIPAL

CHINMAYA VIDYALAYA, CHINMAYA GARDENS  
KOLAZHY, THRISSUR

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



MANAGER  
CHINMAYA VIDYALAYA  
KOLAZHY  
THRISSUR-680 010

Ushakumari  
USHAKUMARI P  
Principal  
Chinmaya Vidyalaya  
Kolazhy P. O.  
Thrikkur-680010





**KERALA WATER AUTHORITY  
QUALITY CONTROL DISTRICT LABORATORY**

KIZHAKKUMPATTUKARA THRISSUR

Telephone No - 0487-2338380, E-mail - kwa.qc.tsr@gmail.com



TC-10415

**Test Report**

Test Report. No :KWA/QCDL/TSR/ 3655/2024

ULR No.: TC1041524000003236F.


Report Date: 23.05.2024

<p align="center"><b>Chinmaya Vidyalaya, Kolazhy, Mob:9895775278</b></p>			1. Date of receipt : 20.05.2024		
			2. Sampling done by : The Customer		
			3. UID No.of Sample: KWA/QCDL/TSR/S-003655/2024		
			4. Source of sample : Open Well		
			5. Sample condition : Good		
			6. Name of sample : Drinking water		
			7. Purpose of test : Commercial		
			8. Sample quantity : 2 litre		
			9. Test performing dates From : 21.05.2024 To : 21.05.2024		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Turbidity	(NTU)	IS 3025 (part 10) - 2023 Nephelometric method	1	0.60
2	pH at 25°C		IS 3025 (part 11) - 2022 Electrometric method	6.5 to 8.5	7.4
3	Total Hardness (as Ca CO <sub>3</sub> )	(mg/litre)	IS 3025 (part 21)-2009 (Reaffirmed. 2019)EDTA titration method	200	57.0
4	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) - 1988 (Reaffirmed. 2019) Argentometric titration	250	22.0
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) - 2024 (Reaffirmed. 2019) 1,10 Phenanthroline method	1.0	0.00
6	Nitrate (as NO <sub>3</sub> )	(mg/litre)	APHA 4500 - NO <sub>3</sub> B.Ultraviolet screening method	45	4.7

Remarks:-All tested parameters are within the acceptable limit.

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



\* End of Report \*

Authorized By: *Ragesh M.K*  
Quality Manager,  
Quality Control District Laboratory  
Kerala Water Authority  
Thirissur - 680 005

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Amend.No: 05	Amend Date: 17.05.2024	Page 1 of 1





**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LABORATORY**  
KIZHAKKUMPATTUKARA THRISSUR  
Telephone No - 0487-2338380, E-mail - kwa.qc.tsr@gmail.com

**Test Report**

Test Report. No : KWA/QCDL/TSR/3655/2024

Report Date : 23.05.2024

Customer Name & Address		1. Date of receipt : 20.05.2024			
Chinmaya Vidyalaya, Kolazhy, Mob:9895775278		2. Sampling done by : The Customer			
		3. UID No.of Sample: KWA/QCDL/TSR/S-003655/2024			
		4. Source of sample : Open Well			
		5. Sample condition : Good			
		6. Name of sample : Drinking water			
		7. Purpose of test : Commercial			
		8. Sample quantity : 2 litre			
		9. Test performing dates			
				From : 21.05.2024	To : 21.05.2024
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14) - 2013 (Reaffirmed. 2019) Electrometric method	-	190.0

Remark

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:

\* End of Report \*

Authorized By

*[Signature]*  
Quality Manager,  
Quality Control District Laboratory  
Kerala Water Authority  
Thrissur - 680 005

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Amend.No: 04	Amend Date: 27.01.2024	Page 1 of 1







**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LABORATORY**

KIZHAKKUMPATTUKARA, THRISSUR

Telephone No - 0487-2338380, E-mail -kwa.qc.tsr@gmail.com

Test Report

Test Report. No :KWA/QCDL/TSR/3655/2024

Report Date : 23.05.2024

<b>Customer Name &amp; Address</b>		1. Date of receipt : 20.05.2024		
<b>Chinmaya Vidyalaya, Kolazhy, Mob:9895775278</b>		2. Sampling done by : The Customer		
		3. UID No.of Sample: KWA/QCDL/TSR/S-003655/2024		
		4. Source of sample : Open Well		
		5. Sample condition : Good		
		6. Name of sample : Drinking water		
		7. Purpose of test : Commercial		
		8. Sample Quantity :100ml		
		9. Test Performing Dates From :20.05.2024 To : 22.05.2024		
		Sl. No.	Parameters	Acceptable limits as per-IS 10500-2012
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	Not Detected
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	Not Detected

Remarks:-Coliform and Ecoli bacteria not detected.


*NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.*

Reviewed by:

*[Signature]*  
Quality Manager,  
Quality Control District Laboratory  
Kerala Water Authority  
Thrissur - 680 005

\* End of Report \*

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Rev.No: 00	Rev Date: 00	Page 1 of 1



*[Signature]*  
**MANAGER**  
**CHINMAYA VIDYALAYA**  
**KOLAZHY**  
**THRISSUR-680 010**

*[Signature]*  
**USHAKUMARI P**  
Principal  
Chinmaya Vidyalaya  
Kolazhy P. O.  
Thrissur-680010

